

Govt. Of Bihar
DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)
Public Health Engineering Department
P.H. DIVISION, GAYA

Physico-Chemical and Bacteriological Examination Report of Drinking Water Samples of Gaya																			
Sample Collected By :	Rakesh kumar	Guardian Public School Dariyapur,Gurua Road Cherki								Sample Received on : 16/04/26									
Sample no	Block Name	Panchayat Name	Village	Wardno	Turb.	Conductivity	TDS	Hardness	Calcium	Magnesium	Chloride	Alkalinity	Fluoride	PH	Nitrate	Iron	Sulphate	Bacteria (+/-)	Remarks
1	Gurua	-	Dariyapur	-	0.73	1015	659	316	110	10.59	133	332	0.53	7.62	-	-	70	Absent	
Reporting Date :	20.04.26	Desirable Limit			1.00 NTU	-	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200 (mg/l)	1.00 (mg/l)	6.5-8.5	45 (mg/l)	1.00 (mg/l)	200 (mg/l)	Absent	
Permissible Limit in absence of alternate source IS:10500:2012					5.00 NTU	-	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)	600 (mg/l)	1.50 (mg/l)	NR	NR	NR	400 (mg/l)	Absent	

*NR-No Relaxation.,BDL-Below Detection Limit

Rakesh Kumar
Chemist 20.04.26

P.H.Division, Gaya

जल नमूना का संग्रह दिनांक...16.04.26
Rakesh Kumar के द्वारा किया गया है।